

 <p>City of Santa Monica[®]</p>	<p>City of Santa Monica</p> <p>Plumbing Fixture Flow Rates Residential Mandatory Measures 2013 California Green Building Standards Code</p>	 <p>Eff. 1-01-14</p>
--	---	---

FIXTURE FLOW RATES (SECT 4.303)	
FIXTURE TYPE	MAX ALLOW. FLOW RATE
Showerheads	2 gpm @ 80 psi
Lavatory faucets	1.5 gpm @ 60 psi ¹
Lavatory faucets, common & Public Use	0.5 gpm @ 60 psi ³
Kitchen faucets	1.8 gpm @ 60 psi ^{2,3}
Gravity tank type water closets	1.28 gallons/flush ⁴
Flushometer tank type water closet	1.28 gallons/flush ⁴
Flushometer valve water closet	1.28 gallons/flush ⁴
Urinals	0.5 gallons/flush

¹ Lavatory Faucets shall not have a flow rate less than 0.8 gpm @ 20psi.

² Kitchen faucets may temporarily increase flow above the max rate, but not above 2.2gpm @60psi and must default to a max flow rate of 1.8gpm @60psi.

³ Where complying faucets are unavailable, aerators may be used to achieve reduction

⁴ Includes single and dual flush water closets with an effective flush of 1.28 gallons or less.