

Spray to Drip Irrigation Conversion Rebate Installation Checklist



The installation checklist helps ensure that your project will meet the final inspection requirements of the Spray to Drip Rebate Program. The irrigation installer must submit a signed copy of this checklist in order to schedule a final inspection.

Please scan and email the signed document to savewater@smgov.net. The project applicant will be contacted to schedule an inspection. Please call 310-458-8972 x 1 if you have any questions.

Project Installer Information

Rebate Project Address:	Date:
Installer/Contractor Name/Homeowner DIY:	Company Name (if applicable):
Daytime Phone Number:	Email:
Santa Monica Business License # (optional):	C-27 License # (optional):

Section 1: GENERAL IRRIGATION
<input type="checkbox"/> Spray irrigation is completely removed and/or capped in the converted area.
<input type="checkbox"/> Only drip irrigation is used in the converted area.
<input type="checkbox"/> Only professional grade 1/2-inch drip tubing is used in the converted area. (see reverse)
<input type="checkbox"/> Only qualified drip control zone kits are installed. Each kit includes a backflow prevention device, low-flow valve, filter, pressure regulator, and flushing mechanism. (see reverse)
<input type="checkbox"/> The drip control zone has a flow rate that matches the flow rate of the drip zone.
<input type="checkbox"/> The irrigation controller has been reprogrammed for a drip irrigation schedule.
<input type="checkbox"/> Anti-siphon valves are installed 6 inches above the highest drip emitter in the converted area.
<input type="checkbox"/> Drip irrigation filters are easily accessible for servicing.
<input type="checkbox"/> Drip irrigation zones are on their own valve (existing sprinklers or tree bubbler zones must be on separate valves).
<input type="checkbox"/> Where feasible, trees are installed on a separate drip zone valve.

By signing this Checklist form, you confirm the checked requirements have been completed to the City's specification for the project stated on this form. Installer understands that if all the checklist requirements are not met, the project may be denied, and a rebate may not be given to the applicant of the project. If all checklist requirements are not met at the time of inspection, an extension may be given and is at the sole discretion of the City's Water Conservation Unit.

Installer Signature _____ Date _____

FOR INTERNAL USE ONLY			
Date Received:	Processed by:	Approved (Y/N)	Date Approved

Spray to Drip Irrigation Conversion Rebate Installation Checklist



Section 2: APPROVED DRIP IRRIGATION PARTS

IMPORTANT BACKFLOW INFORMATION! All commercial properties must install a master backflow prevention device (“RP”) on the irrigation system. All other properties may use anti-siphon valves for irrigation backflow prevention devices.

APPROVED DRIP CONTROL ZONE KITS with Master Backflow. Properties **with** a master backflow prevention device (“RP”) must use one of the following drip control zone kits.

*Commercial properties must have a reduced pressure backflow preventer for the irrigation system. Indicate which approved drip control zone kits were installed in your project:

	Brand	Model
	Netafim	LVCZS80SF10075-LF/HFHP
	Hunter	PCZ-101-40 or ICZ-101-40-LF
	Rain Bird	XCZ-075-PRF or XCZ-100-PRF
	TORO	DZK-TPV-1-LF
	Landscape Products	LP-VP-1- Drip Zone Kit

APPROVED DRIP CONTROL ZONE KITS without Master Backflow. Properties without a master backflow prevention device (“RP”) must use one of the following drip control zone kits. Anti-siphon valves must be installed a minimum of 6 inches above the highest drip emitter in the converted area.

Indicate which approved drip control zone kits were installed in your project:

	Brand	Model
	Irritrol	2711APRDK-LF
	Hunter	ACZ-075-25/40
	Rain Bird	XACZ-075-PRF
	TORO	DZK-TPV-1-LF

APPROVED DRIP TUBING. DO NOT install ¼-inch “spaghetti” drip tubing or multi-outlet emitters.

Indicate which approved drip tubing which was installed in your project:

	Brand	Model
	Agrifim	Duro Flo Inline CV Series
	Hunter	PLD-CV Dripline Series
	Rain Bird	XFS-CV Dripline Series
	TORO	Drip In PC Brown Dripline Series
	Landscape Products	EZ-ID-CV Dripline Series
	Netafim	Techline HCVXR or CV Series Dripline

APPROVED ZONE FLUSHING DEVICE

Indicate the type of approved zone flushing devices that were installed in your project:

	Figure 8 tubing end clamp
	Flush valve

Spray to Drip Irrigation Conversion Rebate
Installation Checklist

